

Amherst Regional High School

Location	Fixture	Sample Type	Most Recent Testing	
			Date	Lead Results
2nd floor Hallway, left, left pair	Bubbler	Flush	9/8/2016	0.78 ppb
2nd floor Hallway, left, left pair	Bubbler	First Draw	9/8/2016	ND ppb
2nd floor Hallway, left, right pair	Bubbler	First Draw	9/8/2016	0.64 ppb
2nd floor Hallway, right, right pair	Bubbler	Flush	9/8/2016	0.82 ppb
2nd floor Hallway, right, right pair	Bubbler	First Draw	9/8/2016	0.67 ppb
3rd floor Hallway, left, left pair	Bubbler	First Draw	9/8/2016	ND ppb
3rd floor Hallway, left, right pair	Bubbler	First Draw	9/8/2016	ND ppb
3rd floor Hallway, right, left pair	Bubbler	Flush	9/8/2016	0.91 ppb
3rd floor Hallway, right, left pair	Bubbler	First Draw	9/8/2016	0.88 ppb
3rd floor Hallway, right, right pair	Bubbler	Flush	9/8/2016	1.1 ppb
3rd floor Hallway, right, right pair	Bubbler	First Draw	9/8/2016	1.2 ppb
Exercise Room No. 1, left	Bubbler	Flush	9/8/2016	ND ppb
Exercise Room No. 1, left	Bubbler	First Draw	9/8/2016	ND ppb
Exercise Room No. 1, right	Bubbler	First Draw	9/8/2016	ND ppb
Food Prep Sink	Kitchen Faucet	Flush	1/27/2017	ND ppb
Food Prep Sink	Kitchen Faucet	Flush	9/8/2016	0.92 ppb
Food Prep Sink	Kitchen Faucet	First Draw	1/27/2017	1.8 ppb
Food Prep Sink	Kitchen Faucet	First Draw	9/8/2016	7.5 ppb
Gym No. 1, left	Bubbler	Flush	9/8/2016	ND ppb
Gym No. 1, left	Bubbler	First Draw	9/8/2016	0.94 ppb
Gym No. 1, right	Bubbler	First Draw	9/8/2016	2.1 ppb
Hallway near Auditorium, left, right pair	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Auditorium, right, left pair	Bubbler	Flush	9/8/2016	4.5 ppb
Hallway near Auditorium, right, left pair	Bubbler	First Draw	9/8/2016	0.74 ppb
Hallway near Auditorium, right, right pair	Bubbler	Flush	9/8/2016	0.83 ppb
Hallway near Auditorium, right, right pair	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Gym, left	Bubbler	Flush	9/8/2016	0.98 ppb
Hallway near Gym, left	Bubbler	First Draw	9/8/2016	1.2 ppb
Hallway near Gym, right	Bubbler	First Draw	9/8/2016	1.3 ppb
Hallway near Kitchen, left, left pair	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Kitchen, left, right pair	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Kitchen, right, left pair	Bubbler	Flush	9/8/2016	ND ppb
Hallway near Kitchen, right, left pair	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Kitchen, right, right pair	Bubbler	Flush	9/8/2016	ND ppb
Hallway near Kitchen, right, right pair	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Library, left	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Library, right	Bubbler	Flush	9/8/2016	ND ppb
Hallway near Library, right	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Room 176, left	Bubbler	Flush	9/8/2016	ND ppb
Hallway near Room 176, left	Bubbler	First Draw	9/8/2016	ND ppb
Hallway near Room 176, right	Bubbler	First Draw	9/8/2016	ND ppb
Health Room 110A	Faucet	Flush	10/20/2016	ND ppb

Amherst Regional High School

Location	Fixture	Sample Type	Most Recent Testing	
			Date	Lead Results
Health Room 110A	Faucet	First Draw	10/20/2016	1.1 ppb
Health Room, office	Faucet	First Draw	9/8/2016	11 ppb
Heath Room, office	Faucet	Flush	10/20/2016	2.8 ppb
Heath Room, office	Bubbler	First Draw	10/20/2016	14 ppb
Home-Ec Room #1	Faucet	Flush	9/8/2016	0.97 ppb
Home-Ec Room #1	Faucet	First Draw	9/8/2016	8.2 ppb
Home-Ec Room #2	Faucet	Flush	9/8/2016	2 ppb
Home-Ec Room #2	Faucet	First Draw	9/8/2016	4.4 ppb
Home-Ec Room #3	Faucet	Flush	9/8/2016	0.92 ppb
Home-Ec Room #3	Faucet	First Draw	9/8/2016	6.7 ppb
Home-Ec Room #4	Faucet	Flush	9/8/2016	1.4 ppb
Home-Ec Room #4	Faucet	First Draw	9/8/2016	4 ppb
Home-Ec Room #5	Faucet	Flush	9/8/2016	1.2 ppb
Home-Ec Room #5	Faucet	First Draw	9/8/2016	8.9 ppb
Home-Ec Room #6	Faucet	Flush	9/8/2016	1.4 ppb
Home-Ec Room #6	Faucet	First Draw	9/8/2016	12 ppb
Kitchen Kettle	Kitchen Faucet	Flush	9/8/2016	0.56 ppb
Kitchen Kettle	Kitchen Faucet	First Draw	9/8/2016	2.5 ppb

Amherst Regional High School

Location	Fixture	Sample Type	Most Recent Testing	
			Date	Lead Results
Library Work Room	Faucet	Flush	9/8/2016	ND ppb
Library Work Room	Faucet	First Draw	9/8/2016	5 ppb
Men's locker room (lower level), left	Bubbler	First Draw	9/8/2016	0.57 ppb
Men's locker room (lower level), right	Bubbler	Flush	9/8/2016	ND ppb
Men's locker room (lower level), right	Bubbler	First Draw	9/8/2016	0.71 ppb
Men's locker room (upper level)	Bubbler	Flush	1/27/2017	ND ppb
Men's locker room (upper level)	Bubbler	First Draw	1/27/2017	ND ppb
Room 129	Faucet	Flush	9/8/2016	1.9 ppb
Room 129	Faucet	First Draw	9/8/2016	11 ppb
Room 167	Faucet	Flush	9/8/2016	ND ppb
Room 167	Faucet	First Draw	9/8/2016	0.68 ppb
Room 190	Faucet	Flush	9/8/2016	0.72 ppb
Room 190	Faucet	First Draw	9/8/2016	15 ppb
Room 192	Faucet	Flush	9/8/2016	0.6 ppb
Room 192	Faucet	First Draw	9/8/2016	6.5 ppb
Room 193	Faucet	Flush	10/20/2016	ND ppb
Room 193	Faucet	First Draw	10/20/2016	15 ppb
Room 206	Faucet	Flush	9/8/2016	ND ppb
Room 206	Faucet	First Draw	9/8/2016	1.7 ppb
Room 208	Faucet	Flush	9/8/2016	ND ppb
Room 208	Faucet	First Draw	9/8/2016	2.3 ppb
Room 210	Faucet	Flush	9/8/2016	0.67 ppb
Room 210	Faucet	First Draw	9/8/2016	3.1 ppb
Room 218	Faucet	Flush	9/8/2016	ND ppb
Room 218	Faucet	First Draw	9/8/2016	1.6 ppb
Room 219	Faucet	Flush	9/8/2016	0.63 ppb
Room 219	Faucet	First Draw	9/8/2016	2.7 ppb
Teacher Planning Room	Faucet	Flush	9/8/2016	1.5 ppb
Teacher Planning Room	Faucet	First Draw	9/8/2016	8.2 ppb
Women's locker room, left	Bubbler	First Draw	9/8/2016	ND ppb
Women's locker room, right	Bubbler	Flush	9/8/2016	ND ppb
Women's locker room, right	Bubbler	First Draw	9/8/2016	ND ppb