

Amherst Regional High School

Room Location	Fixture	Sample Type	Lead Result	
Room 129	Faucet	Flush	1.9	ppb
Room 129	Faucet	First Draw	11	ppb
Room 167	Faucet	Flush	ND	ppb
Room 167	Faucet	First Draw	0.68	ppb
Room 190	Faucet	Flush	0.72	ppb
Room 190	Faucet	First Draw	15	ppb
Room 192	Faucet	Flush	0.6	ppb
Room 192	Faucet	First Draw	6.5	ppb
Room 193	Faucet	Flush	1.5	ppb
Room 193	Faucet	First Draw	20	ppb
Room 206	Faucet	Flush	ND	ppb
Room 206	Faucet	First Draw	1.7	ppb
Room 208	Faucet	Flush	ND	ppb
Room 208	Faucet	First Draw	2.3	ppb
Room 210	Faucet	Flush	0.67	ppb
Room 210	Faucet	First Draw	3.1	ppb
Room 218	Faucet	Flush	ND	ppb
Room 218	Faucet	First Draw	1.6	ppb
Room 219	Faucet	Flush	0.63	ppb
Room 219	Faucet	First Draw	2.7	ppb
2nd floor Hallway, left, left pair	Bubbler	Flush	0.78	ppb
2nd floor Hallway, left, left pair	Bubbler	First Draw	ND	ppb
2nd floor Hallway, left, right pair	Bubbler	First Draw	0.64	ppb
2nd floor Hallway, right, right pair	Bubbler	Flush	0.82	ppb
2nd floor Hallway, right, right pair	Bubbler	First Draw	0.67	ppb
3rd floor Hallway, left, left pair	Bubbler	First Draw	ND	ppb
3rd floor Hallway, left, right pair	Bubbler	First Draw	ND	ppb
3rd floor Hallway, right, left pair	Bubbler	Flush	0.91	ppb
3rd floor Hallway, right, left pair	Bubbler	First Draw	0.88	ppb
3rd floor Hallway, right, right pair	Bubbler	Flush	1.1	ppb
3rd floor Hallway, right, right pair	Bubbler	First Draw	1.2	ppb
Exercise Room No. 1, left	Bubbler	Flush	ND	ppb
Exercise Room No. 1, left	Bubbler	First Draw	ND	ppb
Exercise Room No. 1, right	Bubbler	First Draw	ND	ppb
Food Prep Sink	Kitchen Faucet	Flush	0.92	ppb
Food Prep Sink	Kitchen Faucet	First Draw	7.5	ppb
Food Prep Sink	Kitchen Faucet	Flush	1.5	ppb
Food Prep Sink	Kitchen Faucet	First Draw	16	ppb
Gym No. 1, left	Bubbler	Flush	ND	ppb
Gym No. 1, left	Bubbler	First Draw	0.94	ppb
Gym No. 1, right	Bubbler	First Draw	2.1	ppb
Hallway near Auditorium, left, right pair	Bubbler	First Draw	ND	ppb
Hallway near Auditorium, right, left pair	Bubbler	Flush	4.5	ppb

Amherst Regional High School

Room Location	Fixture	Sample Type	Lead Result	
Hallway near Auditorium, right, left pair	Bubbler	First Draw	0.74	ppb
Hallway near Auditorium, right, right pair	Bubbler	Flush	0.83	ppb
Hallway near Auditorium, right, right pair	Bubbler	First Draw	ND	ppb
Hallway near Gym, left	Bubbler	Flush	0.98	ppb
Hallway near Gym, left	Bubbler	First Draw	1.2	ppb
Hallway near Gym, right	Bubbler	First Draw	1.3	ppb
Hallway near Kitchen, left, left pair	Bubbler	First Draw	ND	ppb
Hallway near Kitchen, left, right pair	Bubbler	First Draw	ND	ppb
Hallway near Kitchen, right, left pair	Bubbler	Flush	ND	ppb
Hallway near Kitchen, right, left pair	Bubbler	First Draw	ND	ppb
Hallway near Kitchen, right, right pair	Bubbler	Flush	ND	ppb
Hallway near Kitchen, right, right pair	Bubbler	First Draw	ND	ppb
Hallway near Library, left	Bubbler	First Draw	ND	ppb
Hallway near Library, right	Bubbler	Flush	ND	ppb
Hallway near Library, right	Bubbler	First Draw	ND	ppb
Hallway near Room 176, left	Bubbler	Flush	ND	ppb
Hallway near Room 176, left	Bubbler	First Draw	ND	ppb
Hallway near Room 176, right	Bubbler	First Draw	ND	ppb
Health Room	Faucet	Flush	16	ppb
Health Room, office	Faucet	First Draw	11	ppb
Heath Room	Faucet	First Draw	460	ppb
Heath Room, office	Faucet	Flush	3.4	ppb
Heath Room, office	Bubbler	First Draw	17	ppb
Home-Ec Room #1	Faucet	Flush	0.97	ppb
Home-Ec Room #1	Faucet	First Draw	8.2	ppb
Home-Ec Room #2	Faucet	Flush	2	ppb
Home-Ec Room #2	Faucet	First Draw	4.4	ppb
Home-Ec Room #3	Faucet	Flush	0.92	ppb
Home-Ec Room #3	Faucet	First Draw	6.7	ppb
Home-Ec Room #4	Faucet	Flush	1.4	ppb
Home-Ec Room #4	Faucet	First Draw	4	ppb
Home-Ec Room #5	Faucet	Flush	1.2	ppb
Home-Ec Room #5	Faucet	First Draw	8.9	ppb
Home-Ec Room #6	Faucet	Flush	1.4	ppb
Home-Ec Room #6	Faucet	First Draw	12	ppb
Kitchen Kettle	Kitchen Faucet	Flush	0.56	ppb
Kitchen Kettle	Kitchen Faucet	First Draw	2.5	ppb
Library Work Room	Faucet	Flush	ND	ppb
Library Work Room	Faucet	First Draw	5	ppb
Men's locker room (lower level), left	Bubbler	First Draw	0.57	ppb
Men's locker room (lower level), right	Bubbler	Flush	ND	ppb
Men's locker room (lower level), right	Bubbler	First Draw	0.71	ppb
Men's locker room (upper level)	Bubbler	Flush	48	ppb

Amherst Regional High School

Room Location	Fixture	Sample Type	Lead Result	
Men's locker room (upper level)	Bubbler	First Draw	120	ppb
Teacher Planning Room	Faucet	Flush	1.5	ppb
Teacher Planning Room	Faucet	First Draw	8.2	ppb
Training Room, left	Bubbler	First Draw	420	ppb
Training Room, right	Bubbler	Flush	42	ppb
Training Room, right	Bubbler	First Draw	280	ppb
Women's locker room, left	Bubbler	First Draw	ND	ppb
Women's locker room, right	Bubbler	Flush	ND	ppb
Women's locker room, right	Bubbler	First Draw	ND	ppb