

Amherst Regional Middle School

Location	Fixture	Sample Type	Lead Results	
Room C-14	Faucet	First Draw	13	ppb
Room C-14	Faucet	Flush	5.6	ppb
Room C-1L	Faucet	First Draw	130	ppb
Room C-1L	Faucet	Flush	8	ppb
Room C-28	Faucet	First Draw	220	ppb
Room C-28	Faucet	Flush	48	ppb
Family Center	Faucet	First Draw	93	ppb
Family Center	Bubbler	First Draw	120	ppb
Family Center	Faucet	Flush	38	ppb
Room C-7A	Faucet	First Draw	110	ppb
Room C-7A	Faucet	Flush	13	ppb
Boy's Locker Room	Bubbler	First Draw	25	ppb
Boy's Locker Room	Bubbler	Flush	5.3	ppb
Bus Driver Break Room	Faucet	First Draw	1.1	ppb
Bus Driver Break Room	Faucet	Flush	1.5	ppb
Facilities Office	Faucet	First Draw	4.3	ppb
Facilities Office	Faucet	Flush	1.3	ppb
Food Prep, left	Kitchen Faucet	First Draw	19	ppb
Food Prep, left	Kitchen Faucet	Flush	2.3	ppb
Food Prep, right	Kitchen Faucet	First Draw	4.8	ppb
Food Prep, right	Kitchen Faucet	Flush	0.96	ppb
Girl's Locker Room	Bubbler	First Draw	16	ppb
Girl's Locker Room	Bubbler	Flush	8.1	ppb
Hallway near Art Room	Bubbler	First Draw	1.3	ppb
Hallway near Art Room	Bubbler	Flush	1.4	ppb
Hallway near Auditorium, north	Bubbler	First Draw	13	ppb
Hallway near Auditorium, north	Bubbler	Flush	13	ppb
Hallway near Auditorium, south	Bubbler	First Draw	3.7	ppb
Hallway near Auditorium, south	Bubbler	Flush	5.4	ppb
Hallway near Elevator, right	Bubbler	First Draw	8	ppb
Hallway near Elevator, right	Bubbler	Flush	20	ppb
Hallway near Kitchen	Bubbler	First Draw	3.3	ppb

Amherst Regional Middle School

Location	Fixture	Sample Type	Lead Results	
			Value	Unit
Hallway near Kitchen	Bubbler	Flush	4.6	ppb
Hallway near LSSE	Bubbler	First Draw	0.85	ppb
Hallway near LSSE	Bottle Filler	First Draw	0.76	ppb
Hallway near LSSE	Bubbler	Flush	1	ppb
Hallway near Room C-19, left	Bubbler	First Draw	4.8	ppb
Hallway near Room C-19, left	Bubbler	Flush	4.2	ppb
Hallway near Room C-19, right	Bubbler	First Draw	22	ppb
Hallway near Room C-19, right	Bubbler	Flush	6.5	ppb
Hallway near Room C-25, left	Bubbler	First Draw	35	ppb
Hallway near Room C-25, left	Bubbler	Flush	13	ppb
Hallway near Room C-25, right	Bubbler	First Draw	9.4	ppb
Hallway near Room C-25, right	Bubbler	Flush	18	ppb
Hallway near Room C-2M, right	Bubbler	First Draw	4.2	ppb
Hallway near Room C-2M, right	Bubbler	Flush	12	ppb
Hallway near Room C-4, left	Bubbler	First Draw	100	ppb
Hallway near Room C-4, left	Bubbler	Flush	21	ppb
Hallway near Room C-4, right	Bubbler	First Draw	14	ppb
Hallway near Room C-4, right	Bubbler	Flush	13	ppb
Hallway near Wood Shop	Bubbler	First Draw	19	ppb
Hallway near Wood Shop	Bottle Filler	First Draw	15	ppb
Hallway near Wood Shop	Bubbler	Flush	17	ppb
Health Room, by Exam Room	Faucet	First Draw	52	ppb
Health Room, by Exam Room	Faucet	Flush	6.8	ppb
Health Room, right	Faucet	First Draw	60	ppb
Health Room, right	Faucet	Flush	5.9	ppb
Integrated Arts Room, left	Faucet	First Draw	73	ppb
Integrated Arts Room, left	Faucet	Flush	5.1	ppb
Integrated Arts Room, right	Faucet	First Draw	7.4	ppb
Integrated Arts Room, right	Faucet	Flush	5.5	ppb
Janitor Break Room	Faucet	First Draw	31	ppb
Janitor Break Room	Faucet	Flush	3.8	ppb
Kitchen Kettle	Kitchen Faucet	First Draw	1.9	ppb

Amherst Regional Middle School

Location	Fixture	Sample Type	Lead Results	
Kitchen Kettle	Kitchen Faucet	Flush	2.2	ppb
LSSE Break Room	Faucet	First Draw	130	ppb
LSSE Break Room	Faucet	Flush	25	ppb
PD Center	Faucet	First Draw	13	ppb
PD Center	Faucet	Flush	2.4	ppb
Pool, near Boy's Locker Room	Bubbler	First Draw	250	ppb
Pool, near Boy's Locker Room	Bubbler	Flush	16	ppb
Pool, near Girl's Locker Room	Bubbler	First Draw	83	ppb
Pool, near Girl's Locker Room	Bubbler	Flush	21	ppb
Staff Room near Room C-21A	Faucet	First Draw	46	ppb
Staff Room near Room C-21A	Faucet	Flush	11	ppb
Office Mail Room	Faucet	First Draw	20	ppb
Office Mail Room	Faucet	Flush	2.8	ppb