

Fort River Elementary School

Room Location	Fixture	Sample Type	Lead Result	
Room A	Faucet	First Draw	17	ppb
Room A	Bubbler	First Draw	55	ppb
Room A	Faucet	Flush	2.3	ppb
Room B	Faucet	First Draw	12	ppb
Room B	Bubbler	First Draw	29	ppb
Room B	Faucet	Flush	4.6	ppb
Room C-1	Faucet	First Draw	15	ppb
Room C-1	Bubbler	First Draw	28	ppb
Room C-1	Faucet	Flush	2.7	ppb
Room C-2	Bubbler	First Draw	17	ppb
Room C-2	Faucet	First Draw	18	ppb
Room C-2	Faucet	Flush	2.4	ppb
Room C-3	Bubbler	First Draw	18	ppb
Room C-3	Faucet	First Draw	28	ppb
Room C-3	Faucet	Flush	3.3	ppb
Room C-4	Bubbler	First Draw	26	ppb
Room C-4	Faucet	First Draw	38	ppb
Room C-4	Faucet	Flush	3.4	ppb
Room D-1	Faucet	First Draw	28	ppb
Room D-1	Bubbler	First Draw	30	ppb
Room D-1	Faucet	Flush	4	ppb
Room D-2	Faucet	First Draw	28	ppb
Room D-2	Bubbler	First Draw	57	ppb
Room D-2	Faucet	Flush	3.1	ppb
Room D-3	Bubbler	First Draw	29	ppb
Room D-3	Faucet	First Draw	34	ppb
Room D-3	Faucet	Flush	3.7	ppb
Room D-4	Faucet	First Draw	14	ppb
Room D-4	Bubbler	First Draw	29	ppb
Room D-4	Faucet	Flush	1.9	ppb
Room E-1	Faucet	First Draw	36	ppb
Room E-1	Bubbler	First Draw	45	ppb
Room E-1	Faucet	Flush	10	ppb
Room E-2	Bubbler	First Draw	18	ppb
Room E-2	Faucet	First Draw	37	ppb
Room E-2	Faucet	Flush	2.9	ppb
Room E-3	Bubbler	First Draw	30	ppb
Room E-3	Faucet	First Draw	33	ppb
Room E-3	Faucet	Flush	3.8	ppb
Room E-4	Bubbler	First Draw	43	ppb
Room E-4	Faucet	First Draw	45	ppb
Room E-4	Faucet	Flush	9.8	ppb
Room F-1	Faucet	First Draw	26	ppb

Fort River Elementary School

Room Location	Fixture	Sample Type	Lead Result	
Room F-1	Bubbler	First Draw	36	ppb
Room F-1	Faucet	Flush	3.9	ppb
Room F-2	Faucet	First Draw	36	ppb
Room F-2	Bubbler	First Draw	57	ppb
Room F-2	Faucet	Flush	4.6	ppb
Room F-3	Faucet	First Draw	24	ppb
Room F-3	Bubbler	First Draw	32	ppb
Room F-3	Faucet	Flush	3.1	ppb
Room F-4	Faucet	First Draw	21	ppb
Room F-4	Bubbler	First Draw	31	ppb
Room F-4	Faucet	Flush	3.8	ppb
Room G-1	Faucet	First Draw	40	ppb
Room G-1	Bubbler	First Draw	54	ppb
Room G-1	Faucet	Flush	5	ppb
Room G-2	Bubbler	First Draw	31	ppb
Room G-2	Faucet	First Draw	56	ppb
Room G-2	Faucet	Flush	8	ppb
Room G-3	Faucet	First Draw	37	ppb
Room G-3	Bubbler	First Draw	45	ppb
Room G-3	Faucet	Flush	3.9	ppb
Room G-4	Faucet	First Draw	12	ppb
Room G-4	Bubbler	First Draw	49	ppb
Room G-4	Faucet	Flush	2.6	ppb
Room H-1	Faucet	First Draw	20	ppb
Room H-1	Bubbler	First Draw	27	ppb
Room H-1	Faucet	Flush	3.8	ppb
Room H-2	Faucet	First Draw	23	ppb
Room H-2	Bubbler	First Draw	43	ppb
Room H-2	Faucet	Flush	4.7	ppb
Room H-3	Faucet	First Draw	14	ppb
Room H-3	Bubbler	First Draw	22	ppb
Room H-3	Faucet	Flush	2	ppb
Room H-4	Faucet	First Draw	19	ppb
Room H-4	Bubbler	First Draw	32	ppb
Room H-4	Faucet	Flush	2.5	ppb
Room K-2	Faucet	First Draw	24	ppb
Room K-2	Bubbler	First Draw	60	ppb
Room K-2	Faucet	Flush	4.9	ppb
Room K-3	Faucet	First Draw	18	ppb
Room K-3	Bubbler	First Draw	35	ppb
Room K-3	Faucet	Flush	6.1	ppb
Room T-1	Faucet	First Draw	9.8	ppb
Room T-1	Bubbler	First Draw	33	ppb

Fort River Elementary School

Room Location	Fixture	Sample Type	Lead Result	
Room T-1	Faucet	Flush	2.7	ppb
Room CR-1, left	Faucet	First Draw	210	ppb
Room CR-1, left	Faucet	Flush	11	ppb
Room CR-1, right	Faucet	First Draw	39	ppb
Room CR-1, right	Faucet	Flush	3.7	ppb
Art room, left	Faucet	First Draw	9.8	ppb
Art room, left	Faucet	Flush	3.8	ppb
Art room, right	Faucet	First Draw	83	ppb
Art room, right	Faucet	Flush	9.7	ppb
ESL Room	Faucet	First Draw	28	ppb
ESL Room	Faucet	Flush	7.2	ppb
Cafeteria 2	Bubbler	First Draw	7.5	ppb
Cafeteria 2	Bubbler	Flush	7.8	ppb
Cafeteria 3	Bubbler	First Draw	17	ppb
Cafeteria 3	Bubbler	Flush	6.9	ppb
Cooler by Room E, left	Bubbler	First Draw	47	ppb
Cooler by Room E, left	Bubbler	Flush	21	ppb
Cooler by Room E, right	Bubbler	First Draw	66	ppb
Cooler by Room E, right	Bubbler	Flush	11	ppb
Cooler by Room F, left	Bubbler	First Draw	38	ppb
Cooler by Room F, left	Bubbler	Flush	14	ppb
Cooler by Room F, right	Bubbler	First Draw	15	ppb
Cooler by Room F, right	Bubbler	Flush	10	ppb
Health Room, far wall	Faucet	First Draw	13	ppb
Health Room, far wall	Faucet	Flush	1.2	ppb
Health Room, right	Faucet	First Draw	23	ppb
Health Room, right	Faucet	Flush	1.7	ppb
Kitchen Kettle	Kitchen Sink	First Draw	13	ppb
Kitchen Kettle	Kitchen Sink	Flush	9	ppb
Kitchen prep sink, right	Kitchen Sink	First Draw	11	ppb
Kitchen prep sink, right	Kitchen Sink	Flush	1.9	ppb
Kitchen prep, left	Kitchen Sink	First Draw	12	ppb
Kitchen prep, left	Kitchen Sink	Flush	2.3	ppb
Library Work Room	Faucet	First Draw	16	ppb
Library Work Room	Faucet	Flush	2.7	ppb
Staff Work Area	Faucet	First Draw	15	ppb
Staff Work Area	Faucet	Flush	2.9	ppb
Teachers Lounge	Faucet	First Draw	2.5	ppb
Teachers Lounge	Faucet	Flush	1.3	ppb
Vault/break room	Faucet	First Draw	29	ppb
Vault/break room	Faucet	Flush	6.4	ppb