

Pelham Elementary School

Location	Fixture	Sample Type	Lead Results	
Room 3	Faucet	First Draw	0.88	ppb
Room 3	Faucet	Flush	ND	ppb
Room 11	Faucet	First Draw	0.85	ppb
Room 11	Bubbler	First Draw	1.7	ppb
Room 11	Faucet	Flush	ND	ppb
Room 13	Faucet	First Draw	2.2	ppb
Room 13	Bubbler	First Draw	9.8	ppb
Room 13	Faucet	Flush	ND	ppb
Room 15	Faucet	First Draw	1.4	ppb
Room 15	Bubbler	First Draw	1.9	ppb
Room 15	Faucet	Flush	0.61	ppb
Room 17	Faucet	First Draw	1.2	ppb
Room 17	Bubbler	First Draw	0.96	ppb
Room 17	Faucet	Flush	ND	ppb
Room 18, left	Faucet	First Draw	1.4	ppb
Room 18, left	Bubbler	First Draw	11	ppb
Room 18, left	Faucet	Flush	0.64	ppb
Room 18, right	Faucet	First Draw	1.8	ppb
Room 18, right	Faucet	Flush	0.64	ppb
Room 19	Faucet	First Draw	1.2	ppb
Room 19	Faucet	Flush	0.59	ppb
Room 20	Faucet	First Draw	1.8	ppb
Room 20	Bubbler	First Draw	13	ppb
Room 20	Faucet	Flush	ND	ppb
Room 27	Faucet	First Draw	25	ppb
Room 27	Bubbler	First Draw	16	ppb
Room 27	Faucet	Flush	1.6	ppb
Room 28	Faucet	First Draw	1.4	ppb
Room 28	Bubbler	First Draw	3.5	ppb
Room 28	Faucet	Flush	0.53	ppb
Room 29	Faucet	First Draw	1.8	ppb
Room 29	Bubbler	First Draw	6.3	ppb

Pelham Elementary School

Location	Fixture	Sample Type	Lead Results	
Room 29	Faucet	Flush	1.2	ppb
Room 30	Faucet	First Draw	1.8	ppb
Room 30	Bubbler	First Draw	5.5	ppb
Room 30	Faucet	Flush	0.63	ppb
Room 37	Faucet	First Draw	2.4	ppb
Room 37	Faucet	Flush	0.92	ppb
Hallway near Room 13	Bubbler	First Draw	ND	ppb
Hallway near Room 13	Bubbler	Flush	ND	ppb
Hallway near Room 38, left	Bubbler	First Draw	ND	ppb
Hallway near Room 38, left	Bubbler	Flush	ND	ppb
Hallway near Room 38, right	Bubbler	First Draw	ND	ppb
Hallway near Room 38, right	Bubbler	Flush	ND	ppb
Garden Spigot	Faucet	First Draw	11	ppb
Garden Spigot	Faucet	Flush	0.63	ppb
Outdoor Bubbler	Bubbler	First Draw	85	ppb
Outdoor Bubbler	Bubbler	Flush	1.7	ppb