

Crocker Farm Elementary School

| | | | Initial Testing | | | | Resample Testing | | | Re-resample Testing | | |
|---------|---------|-------------|-----------------|--------------|-----|--------------|------------------|--------------|-----|---------------------------------|--------------|-----|
| | Fixture | Sample Type | Date | Lead Results | | Action Taken | Date | Lead Results | | Date | Lead Results | |
| Room 30 | Bubbler | First Draw | 8/3/2016 | 13 | ppb | Turned off | 9/29/2016 | 62 | ppb | Fixture below AL, not retested. | | |
| Room 30 | Faucet | First Draw | 8/3/2016 | 32 | ppb | Turned off | 9/29/2016 | 4 | ppb | 11/15/2016 | 12 | ppb |
| Room 30 | Faucet | Flush | 8/3/2016 | 2.2 | ppb | Turned off | 9/29/2016 | 1.7 | ppb | 11/15/2016 | 1.9 | ppb |

Pink highlight=lead testing exceeded Action Level (15 ppd)

Red text=fixture turned off after initial testing