

Wildwood Elementary School

Location	Fixture	Sample Type	Resample Testing	
			Date	Lead Results
Room C-1	Faucet	Flush	3/2/2017	< 1.0 ppb
Room C-1	Bubbler	First Draw	3/2/2017	9.2 ppb
Room C-2	Faucet	Flush	3/2/2017	1 ppb
Room C-2	Bubbler	First Draw	3/2/2017	8.2 ppb
Room C-4	Faucet	Flush	3/2/2017	1.7 ppb
Room C-4	Bubbler	First Draw	3/2/2017	16.2 ppb
Room C-3	Faucet	Flush	3/2/2017	2.5 ppb
Room C-3	Bubbler	First Draw	3/2/2017	6.7 ppb
Room D-1	Faucet	Flush	3/2/2017	1.9 ppb
Room D-1	Bubbler	First Draw	3/2/2017	10.9 ppb
Room D-2	Faucet	Flush	3/2/2017	2.4 ppb
Room D-2	Bubbler	First Draw	3/2/2017	21.3 ppb
Room E-1	Faucet	Flush	3/2/2017	1.3 ppb
Room E-1	Faucet	First Draw	3/2/2017	3.8 ppb
Room E-1	Bubbler	First Draw	3/2/2017	26.2 ppb
Room E-4	Faucet	Flush	3/2/2017	1.9 ppb
Room E-4	Faucet	First Draw	3/2/2017	2.3 ppb
Room E-4	Bubbler	First Draw	3/2/2017	4.2 ppb
Room E-3	Faucet	Flush	3/2/2017	1.3 ppb
Room E-3	Bubbler	First Draw	3/2/2017	2.7 ppb
Room F-3	Faucet	Flush	3/2/2017	11.5 ppb
Room F-3	Faucet	First Draw	3/2/2017	6.3 ppb
Room F-3	Bubbler	First Draw	3/2/2017	7.9 ppb
Room F-4	Faucet	Flush	3/2/2017	4.9 ppb
Room F-4	Faucet	First Draw	3/2/2017	8.4 ppb
Room F-4	Bubbler	First Draw	3/2/2017	193 ppb
Room F-2	Faucet	Flush	3/2/2017	< 1.0 ppb
Room F-2	Bubbler	First Draw	3/2/2017	3.8 ppb
Room G-3	Faucet	Flush	3/2/2017	3.4 ppb
Room G-3	Faucet	First Draw	3/2/2017	1 ppb
Room G-3	Bubbler	First Draw	3/2/2017	1.7 ppb
Room G-2	Faucet	Flush	3/2/2017	< 1.0 ppb
Room G-2	Bubbler	First Draw	3/2/2017	8.5 ppb
Room G-1	Faucet	Flush	3/2/2017	< 1.0 ppb
Room G-1	Bubbler	First Draw	3/2/2017	< 1.0 ppb
Room H-3	Faucet	Flush	3/2/2017	7.8 ppb
Room H-3	Faucet	First Draw	3/2/2017	< 1.0 ppb
Room H-4	Faucet	Flush	3/2/2017	4.3 ppb
Room H-4	Bubbler	First Draw	3/2/2017	21.8 ppb
ELL Room, right	Faucet	Flush	3/2/2017	5.3 ppb
ELL Room, right	Faucet	First Draw	3/2/2017	7.3 ppb
ELL Room, left	Faucet	Flush	3/2/2017	<1.0 ppb
ELL Room, left	Faucet	First Draw	3/2/2017	6.2 ppb