

Amherst Regional High School

Location	Fixture	Sample Type	Initial Testing				Resample Testing		
			Date	Lead Results		Action Taken	Date	Lead Results	
Room 193	Faucet	First Draw	9/8/2016	20	ppb	Turned off	10/20/2016	15	ppb
Room 193	Faucet	Flush	9/8/2016	1.5	ppb	Turned off	10/20/2016	ND	ppb
Food Prep Sink	Kitchen Faucet	First Draw	9/8/2016	16	ppb	Turned off	10/20/2016	25	ppb
Food Prep Sink	Kitchen Faucet	Flush	9/8/2016	1.5	ppb	Turned off	10/20/2016	1.5	ppb
Heath Room	Faucet	First Draw	9/8/2016	460	ppb	Turned off	10/20/2016	100	ppb
Health Room	Faucet	Flush	9/8/2016	16	ppb	Turned off	10/20/2016	10	ppb
Heath Room, office	Bubbler	First Draw	9/8/2016	17	ppb	Flushing Protocol	10/20/2016	14	ppb
Health Room, office	Faucet	First Draw	9/8/2016	11	ppb	Flushing Protocol	Fixture below AL, not retested.		
Health Room, office	Faucet	Flush	9/8/2016	3.4	ppb	Flushing Protocol	10/20/2016	2.8	ppb
Health Room 110A	Faucet	First Draw	Not tested in initial testing				10/20/2016	1.1	ppb
Health Room 110A	Faucet	Flush					10/20/2016	ND	ppb
Health Room 110B	Faucet	First Draw	Not tested in initial testing				10/20/2016	18	ppb
Health Room 110B	Faucet	Flush					10/20/2016	2.3	ppb
Men's locker room (upper level)	Bubbler	First Draw	9/8/2016	120	ppb	Turned off	10/20/2016	88	ppb
Men's locker room (upper level)	Bubbler	Flush	9/8/2016	48	ppb	Turned off	10/20/2016	49	ppb
Training Room, left	Bubbler	First Draw	9/8/2016	420	ppb	Turned off	Fixture removed.		
Training Room, right	Bubbler	First Draw	9/8/2016	280	ppb	Turned off	Fixture removed.		
Training Room, right	Bubbler	Flush	9/8/2016	42	ppb	Turned off	Fixture removed.		

Pink highlight = lead testing exceeded Action Level (15 ppb)

Red text = fixture turned off after initial testing