

Amherst Regional Middle School

Location	Fixture	Sample Type	Initial Testing				Resample Testing		
			Date	Lead Results		Action Taken	Date	Lead Results	
Boy's Locker Room	Bubbler	First Draw	9/7/2016	25	ppb	Flushing Protocol	11/15/2016	8.7	ppb
Boy's Locker Room	Bubbler	Flush	9/7/2016	5.3	ppb	Flushing Protocol	11/15/2016	3.1	ppb
Family Center	Bubbler	First Draw	9/7/2016	120	ppb	Turned off	11/15/2016	120	ppb
Family Center	Faucet	First Draw	9/7/2016	93	ppb	Turned off	11/15/2016	35	ppb
Family Center	Faucet	Flush	9/7/2016	38	ppb	Turned off	11/15/2016	48	ppb
Food Prep, left	Kitchen Faucet	First Draw	9/7/2016	19	ppb	Flushing Protocol	11/15/2016	19	ppb
Food Prep, left	Kitchen Faucet	Flush	9/7/2016	2.3	ppb	Flushing Protocol	11/15/2016	3.1	ppb
Girl's Locker Room (hallway)	Bubbler	First Draw	9/7/2016	16	ppb	Flushing Protocol	11/15/2016	12	ppb
Girl's Locker Room (hallway)	Bubbler	Flush	9/7/2016	8.1	ppb	Flushing Protocol	11/15/2016	5.5	ppb
Girl's Locker Room (inside)	Bubbler	First Draw	Not tested in initial testing				11/15/2016	6.3	ppb
Girl's Locker Room (inside)	Bubbler	Flush					11/15/2016	4	ppb
Hallway near Elevator, right	Bubbler	First Draw	9/7/2016	8	ppb	Turned off	11/15/2016	20	ppb
Hallway near Elevator, right	Bubbler	Flush	9/7/2016	20	ppb	Turned off	11/15/2016	2.1	ppb
Hallway near Room C-19, right	Bubbler	First Draw	9/7/2016	22	ppb	Flushing Protocol	11/15/2016	3.4	ppb
Hallway near Room C-19, right	Bubbler	Flush	9/7/2016	6.5	ppb	Flushing Protocol	11/15/2016	3.6	ppb
Hallway near Room C-25, left	Bubbler	First Draw	9/7/2016	35	ppb	Turned off	11/15/2016	29	ppb
Hallway near Room C-25, left	Bubbler	Flush	9/7/2016	13	ppb	Turned off	fixtures 042 and 043 connected.		
Hallway near Room C-25, right	Bubbler	First Draw	9/7/2016	9.4	ppb	Turned off	11/15/2016	13	ppb
Hallway near Room C-25, right	Bubbler	Flush	9/7/2016	18	ppb	Turned off	11/15/2016	13	ppb
Hallway near Room C-4, left	Bubbler	First Draw	9/7/2016	100	ppb	Turned off	11/15/2016	79	ppb
Hallway near Room C-4, left	Bubbler	Flush	9/7/2016	21	ppb	Turned off	11/15/2016	16	ppb
Hallway near Wood Shop	Bubbler	First Draw	9/7/2016	19	ppb	Turned off	11/15/2016	7.2	ppb
Hallway near Wood Shop	Bottle Filler	First Draw	9/7/2016	15	ppb	Turned off	Fixture below AL, not retested.		
Hallway near Wood Shop	Bubbler	Flush	9/7/2016	17	ppb	Turned off	11/15/2016	9.4	ppb
Health Room, by Exam Room	Faucet	First Draw	9/7/2016	52	ppb	Flushing Protocol	11/15/2016	58	ppb
Health Room, by Exam Room	Faucet	Flush	9/7/2016	6.8	ppb	Flushing Protocol	11/15/2016	4.8	ppb
Health Room, right	Faucet	First Draw	9/7/2016	60	ppb	Flushing Protocol	11/15/2016	31	ppb
Health Room, right	Faucet	Flush	9/7/2016	5.9	ppb	Flushing Protocol	11/15/2016	3.6	ppb
Integrated Arts Room, left	Faucet	First Draw	9/7/2016	73	ppb	Flushing Protocol	11/15/2016	62	ppb
Integrated Arts Room, left	Faucet	Flush	9/7/2016	5.1	ppb	Flushing Protocol	11/15/2016	9	ppb
Janitor Break Room	Faucet	First Draw	9/7/2016	31	ppb	Flushing Protocol	11/15/2016	17	ppb
Janitor Break Room	Faucet	Flush	9/7/2016	3.8	ppb	Flushing Protocol	11/15/2016	3.5	ppb

Amherst Regional Middle School

Location	Fixture	Sample Type	Initial Testing				Resample Testing	
			Date	Lead Results		Action Taken	Date	Lead Results
LSSE Break Room	Faucet	First Draw	9/7/2016	130	ppb	Turned off	11/15/2016	130 ppb
LSSE Break Room	Faucet	Flush	9/7/2016	25	ppb	Turned off	11/15/2016	16 ppb
Office Mail Room	Faucet	First Draw	9/7/2016	20	ppb	Flushing Protocol	11/15/2016	8.4 ppb
Office Mail Room	Faucet	Flush	9/7/2016	2.8	ppb	Flushing Protocol	11/15/2016	2.5 ppb
Pool, near Boy's Locker Room	Bubbler	First Draw	9/7/2016	250	ppb	Turned off	11/15/2016	98 ppb
Pool, near Boy's Locker Room	Bubbler	Flush	9/7/2016	16	ppb	Turned off	11/15/2016	12 ppb
Pool, near Girl's Locker Room	Bubbler	First Draw	9/7/2016	83	ppb	Turned off	11/15/2016	130 ppb
Pool, near Girl's Locker Room	Bubbler	Flush	9/7/2016	21	ppb	Turned off	11/15/2016	23 ppb
Room C-1L	Faucet	First Draw	9/7/2016	130	ppb	Flushing Protocol	11/15/2016	62 ppb
Room C-1L	Faucet	Flush	9/7/2016	8	ppb	Flushing Protocol	11/15/2016	5 ppb
Room C-28	Faucet	First Draw	9/7/2016	220	ppb	Turned off	11/15/2016	50 ppb
Room C-28	Faucet	Flush	9/7/2016	48	ppb	Turned off	11/15/2016	35 ppb
Room C-7A	Faucet	First Draw	9/7/2016	110	ppb	Flushing Protocol	11/15/2016	42 ppb
Room C-7A	Faucet	Flush	9/7/2016	13	ppb	Flushing Protocol	11/15/2016	11 ppb
Staff Room near Room C-21A	Faucet	First Draw	9/7/2016	46	ppb	Flushing Protocol	11/15/2016	11 ppb
Staff Room near Room C-21A	Faucet	Flush	9/7/2016	11	ppb	Flushing Protocol	11/15/2016	3.3 ppb