

## Fort River Elementary School

Location	Fixture	Sample Type	Initial Testing				Resample Testing			Re-Resample Testing	
			Date	Lead Results		Action Taken	Date	Lead Results		Date	Lead Results
Cooler by Room E, left	Bubbler	First Draw	9/2/2016	47	ppb	Turned off	9/30/2016	70	ppb	11/15/2016	50 ppb
Cooler by Room E, left	Bubbler	Flush	9/2/2016	21	ppb	Turned off	9/30/2016	11	ppb	11/15/2016	10 ppb
Cooler by Room E, right	Bubbler	First Draw	9/2/2016	66	ppb	Flushing Protocol	9/30/2016	46	ppb	11/15/2016	38 ppb
Cooler by Room E, right	Bubbler	Flush	9/2/2016	11	ppb	Flushing Protocol	9/30/2016	8	ppb	11/15/2016	9 ppb
Cooler by Room F, left	Bubbler	First Draw	9/2/2016	38	ppb	Flushing Protocol	9/30/2016	36	ppb	11/15/2016	42 ppb
Cooler by Room F, left	Bubbler	Flush	9/2/2016	14	ppb	Flushing Protocol	9/30/2016	10	ppb	11/15/2016	10 ppb
Cooler by Room F, right	Bubbler	First Draw	Not tested in initial testing				9/30/2016	12	ppb	Fixture below AL, not retested.	
Cooler by Room F, right	Bubbler	Flush					9/30/2016	7.3	ppb	Fixture below AL, not retested.	
Room F-1	Bubbler	First Draw	9/2/2016	36	ppb	Flushing Protocol	9/30/2016	26	ppb	11/15/2016	9.4 ppb
Room F-1	Faucet	First Draw	9/2/2016	26	ppb	Flushing Protocol	9/30/2016	12	ppb	Fixture below AL, not retested.	
Room F-1	Faucet	Flush	9/2/2016	3.9	ppb	Flushing Protocol	9/30/2016	4.7	ppb	11/15/2016	1.5 ppb
Room F-2	Bubbler	First Draw	9/2/2016	57	ppb	Flushing Protocol	9/30/2016	40	ppb	11/15/2016	6.9 ppb
Room F-2	Faucet	First Draw	9/2/2016	36	ppb	Flushing Protocol	9/30/2016	16	ppb	11/15/2016	2.2 ppb
Room F-2	Faucet	Flush	9/2/2016	4.6	ppb	Flushing Protocol	9/30/2016	2.7	ppb	11/15/2016	ND ppb
Room F-3	Bubbler	First Draw	9/2/2016	32	ppb	Flushing Protocol	9/30/2016	21	ppb	11/15/2016	5.8 ppb
Room F-3	Faucet	First Draw	9/2/2016	24	ppb	Flushing Protocol	9/30/2016	19	ppb	11/15/2016	3.7 ppb
Room F-3	Faucet	Flush	9/2/2016	3.1	ppb	Flushing Protocol	9/30/2016	2.6	ppb	11/15/2016	1.3 ppb
Room F-4	Bubbler	First Draw	9/2/2016	31	ppb	Flushing Protocol	9/30/2016	20	ppb	11/15/2016	5.7 ppb
Room F-4	Faucet	First Draw	9/2/2016	21	ppb	Flushing Protocol	9/30/2016	8.8	ppb	Fixture below AL, not retested.	
Room F-4	Faucet	Flush	9/2/2016	3.8	ppb	Flushing Protocol	9/30/2016	3.8	ppb	11/15/2016	2.5 ppb
Room G-1	Bubbler	First Draw	9/2/2016	54	ppb	Flushing Protocol	9/30/2016	71	ppb	11/15/2016	19 ppb
Room G-1	Faucet	First Draw	9/2/2016	40	ppb	Flushing Protocol	9/30/2016	20	ppb	11/15/2016	8.8 ppb
Room G-1	Faucet	Flush	9/2/2016	5	ppb	Flushing Protocol	9/30/2016	3.3	ppb	11/15/2016	1.4 ppb
Room G-2	Bubbler	First Draw	9/2/2016	31	ppb	Flushing Protocol	9/30/2016	28	ppb	11/15/2016	64 ppb
Room G-2	Faucet	First Draw	9/2/2016	56	ppb	Flushing Protocol	9/30/2016	20	ppb	11/15/2016	5 ppb
Room G-2	Faucet	Flush	9/2/2016	8	ppb	Flushing Protocol	9/30/2016	3.5	ppb	11/15/2016	4.3 ppb
Room G-3	Bubbler	First Draw	9/2/2016	45	ppb	Flushing Protocol	9/30/2016	73	ppb	11/15/2016	8.3 ppb
Room G-3	Faucet	First Draw	9/2/2016	37	ppb	Flushing Protocol	9/30/2016	18	ppb	11/15/2016	3.7 ppb
Room G-3	Faucet	Flush	9/2/2016	3.9	ppb	Flushing Protocol	9/30/2016	3	ppb	11/15/2016	1.1 ppb
Room G-4	Bubbler	First Draw	9/2/2016	49	ppb	Flushing Protocol	9/30/2016	36	ppb	11/15/2016	16 ppb
Room G-4	Faucet	First Draw	9/2/2016	12	ppb	Flushing Protocol	9/30/2016	5.5	ppb	Fixture below AL, not retested.	
Room G-4	Faucet	Flush	9/2/2016	2.6	ppb	Flushing Protocol	9/30/2016	1.7	ppb	11/15/2016	ND ppb

Pink highlight = lead testing exceeded Action Level (15 ppb)

Red text = fixture turned off after initial testing