

Wildwood Elementary School

Room Location	Fixture	Sample Type	Lead Result	
Room A	Faucet	First Draw	3.9	ppb
Room A	Bubbler	First Draw	54	ppb
Room A	Faucet	Flush	1.3	ppb
Room B	Bubbler	First Draw	11	ppb
Room B	Faucet	First Draw	12	ppb
Room B	Faucet	Flush	1.5	ppb
Room C-1	Faucet	First Draw	4.4	ppb
Room C-1	Bubbler	First Draw	17	ppb
Room C-1	Faucet	Flush	1.1	ppb
Room C-2	Faucet	First Draw	6.8	ppb
Room C-2	Bubbler	First Draw	16	ppb
Room C-2	Faucet	Flush	0.99	ppb
Room C-3	Faucet	First Draw	9.5	ppb
Room C-3	Bubbler	First Draw	25	ppb
Room C-3	Faucet	Flush	1.3	ppb
Room C-4	Faucet	First Draw	9	ppb
Room C-4	Bubbler	First Draw	33	ppb
Room C-4	Faucet	Flush	2.1	ppb
Room D-1	Faucet	First Draw	5.9	ppb
Room D-1	Bubbler	First Draw	16	ppb
Room D-1	Faucet	Flush	1.2	ppb
Room D-2	Faucet	First Draw	8.9	ppb
Room D-2	Bubbler	First Draw	39	ppb
Room D-2	Faucet	Flush	2.2	ppb
Room D-3	Faucet	First Draw	5.2	ppb
Room D-3	Bubbler	First Draw	14	ppb
Room D-3	Faucet	Flush	1.3	ppb
Room D-4	Bubbler	First Draw	12	ppb
Room D-4	Faucet	First Draw	14	ppb
Room D-4	Faucet	Flush	2.2	ppb

Wildwood Elementary School

Room Location	Fixture	Sample Type	Lead Result	
Room E-1	Faucet	First Draw	16	ppb
Room E-1	Bubbler	First Draw	38	ppb
Room E-1	Faucet	Flush	2.6	ppb
Room E-2	Faucet	First Draw	4.8	ppb
Room E-2	Bubbler	First Draw	8.7	ppb
Room E-2	Faucet	Flush	1	ppb
Room E-3	Faucet	First Draw	15	ppb
Room E-3	Bubbler	First Draw	23	ppb
Room E-3	Faucet	Flush	6.1	ppb
Room E-4	Bubbler	First Draw	23	ppb
Room E-4	Faucet	First Draw	65	ppb
Room E-4	Faucet	Flush	10	ppb
Room F-1	Faucet	First Draw	10	ppb
Room F-1	Bubbler	First Draw	14	ppb
Room F-1	Faucet	Flush	1.4	ppb
Room F-2	Faucet	First Draw	7.1	ppb
Room F-2	Bubbler	First Draw	43	ppb
Room F-2	Faucet	Flush	4.1	ppb
Room F-3	Faucet	First Draw	30	ppb
Room F-3	Bubbler	First Draw	50	ppb
Room F-3	Faucet	Flush	11	ppb
Room F-4	Faucet	First Draw	28	ppb
Room F-4	Bubbler	First Draw	53	ppb
Room F-4	Faucet	Flush	7.9	ppb
Room G-1	Faucet	First Draw	12	ppb
Room G-1	Bubbler	First Draw	30	ppb
Room G-1	Faucet	Flush	1.5	ppb
Room G-2	Faucet	First Draw	10	ppb
Room G-2	Bubbler	First Draw	31	ppb
Room G-2	Faucet	Flush	3.1	ppb

Wildwood Elementary School

Room Location	Fixture	Sample Type	Lead Result	
Room G-3	Bubbler	First Draw	19	ppb
Room G-3	Faucet	First Draw	36	ppb
Room G-3	Faucet	Flush	2.3	ppb
Room G-4	Bubbler	First Draw	5.4	ppb
Room G-4	Faucet	First Draw	7.3	ppb
Room G-4	Faucet	Flush	0.74	ppb
Room H-1	Faucet	First Draw	10	ppb
Room H-1	Bubbler	First Draw	25	ppb
Room H-1	Faucet	Flush	3.1	ppb
Room H-2	Faucet	First Draw	13	ppb
Room H-2	Bubbler	First Draw	17	ppb
Room H-2	Faucet	Flush	2.4	ppb
Room H-3	Bubbler	First Draw	11	ppb
Room H-3	Faucet	First Draw	22	ppb
Room H-3	Faucet	Flush	1.6	ppb
Room H-4	Faucet	First Draw	8	ppb
Room H-4	Bubbler	First Draw	19	ppb
Room H-4	Faucet	Flush	1.7	ppb
Room K-1	Faucet	First Draw	14	ppb
Room K-1	Bubbler	First Draw	44	ppb
Room K-1	Faucet	Flush	1.5	ppb
Room K-2	Faucet	First Draw	17	ppb
Room K-2	Bubbler	First Draw	32	ppb
Room K-2	Faucet	Flush	3.9	ppb
Room K-3	Faucet	First Draw	2.4	ppb
Room K-3	Bubbler	First Draw	40	ppb
Room K-3	Faucet	Flush	0.89	ppb
Teachers Lounge	Faucet	First Draw	49	ppb
Teachers Lounge	Faucet	Flush	15	ppb
Vault Room	Faucet	First Draw	27	ppb
Vault Room	Faucet	Flush	6.1	ppb
Art Room, right	Faucet	First Draw	9.6	ppb
Art Room, right	Faucet	Flush	2.6	ppb
Art Room, left	Faucet	First Draw	43	ppb
Art Room, left	Faucet	Flush	3.7	ppb
Cooler by office, left	Bubbler	First Draw	2.6	ppb
Cooler by office, right	Bubbler	First Draw	1.1	ppb
Cooler by office, right	Bubbler	Flush	2.8	ppb
Cooler near gym, left	Bubbler	First Draw	17	ppb
Cooler near gym, right	Bubbler	First Draw	1.5	ppb
Cooler near gym, right	Bubbler	Flush	2.6	ppb
Dining Room 2	Bubbler	First Draw	2.3	ppb
Dining Room 2	Bubbler	Flush	6.7	ppb

Wildwood Elementary School

Room Location	Fixture	Sample Type	Lead Result	
Dining Room 3	Bubbler	First Draw	3.8	ppb
Dining Room 3	Bubbler	Flush	6.6	ppb
ELL Room, right	Faucet	First Draw	22	ppb
ELL Room, right	Faucet	Flush	2.3	ppb
ELL Room, left	Faucet	First Draw	67	ppb
ELL Room, left	Faucet	Flush	7.2	ppb
Food Prep sink, left	Kitchen Faucet	First Draw	22	ppb
Food Prep sink, left	Kitchen Faucet	Flush	1.6	ppb
Food Prep sink, right	Kitchen Faucet	First Draw	23	ppb
Food Prep sink, right	Kitchen Faucet	Flush	3.6	ppb
Green Room	Faucet	First Draw	64	ppb
Green Room	Faucet	Flush	4	ppb
Health Room counter sink	Faucet	First Draw	26	ppb
Health Room counter sink	Faucet	Flush	1.9	ppb
Kitchen Kettle	Kitchen Faucet	First Draw	18	ppb